



Sanitary Sewer Overflow Annual Report

Division of Surface Water

Date: 01/20/2022		
Facility Name: Dover WWTP		
Ohio NPDES Permit Number: OPD00005*ND		
Period Covered by Report: 01/01/2021 - 01/01/2022		
Contact Person: Trevor Klar		Title: Superintendent
Mailing Address: 100 N. Tuscarawas Ave		
City: Dover	State: OH	Zip Code: 44622
Country: USA		
Sanitary Sewer Overflows Spreadsheet(attachment) :		
Water In Basement Occurrences Spreadsheet(attachment) : WIBOccurrences 2021.xlsm		
Narrative analysis of WIB patterns by location, frequency and cause: Root infiltration into city's sewer main by improperly abandoned home sewer lateral. A home was torn down and the sewer lateral was not properly capped. This is a rare occurrence, frequency would be approximated to 1 occurrence per 10 years.		
ADDITIONAL INFORMATION		
Please add any additional comments or attachments below.		
Certification		
I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately responsible for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.		
Name: Trevor Klar		Title: Water/Wastewater Superintendent
Signature(Electronically submitted by): Trevor Klar (User ID: trevorxl)		Submission Date: 08/30/2023